



# CHERRY HILL FIRE MARSHAL'S OFFICE

## STANDPIPE SYSTEM/HOSE CABINET TEST REPORT

*Only this document will be accepted by the Cherry Hill Fire Prevention Division for annual testing purposes as required by the New Jersey Uniform Fire Safety Code and applicable N.F.P.A. standards.*

PROPERTY NAME: \_\_\_\_\_ DATE OF INSPECTION: \_\_\_\_/\_\_\_\_/\_\_\_\_

PROPERTY ADDRESS: \_\_\_\_\_ INSPECTOR: \_\_\_\_\_

TESTING AGENCY NAME: \_\_\_\_\_

NJ-DFS BUSINESS PERMIT # \_\_\_\_\_ PHONE # \_\_\_\_\_

TESTING AGENCY ADDRESS: \_\_\_\_\_

**\*\*ALL STANDPIPE SYSTEMS SHALL MEET THE FLOW DEMANDS REQUIRED AT THE TIME OF INSTALLATION.**

1. TYPE OF SYSTEM: ☐ WET ☐ DRY CLASS I ☐ CLASS II ☐ CLASS III ☐
2. FIRE DEPARTMENT CONNECTION PROPERLY IDENTIFIED? ☐ YES ☐ NO  
LOCATION: \_\_\_\_\_
3. ARE VALVES IDENTIFIED WITH SIGN? ☐ YES ☐ NO
4. ALL STANDPIPES VALVES OPERATED AT ALL LOCATIONS? ☐ YES ☐ NO
5. ALL HOSE STATION VALVES OPERATED AT ALL LOCATIONS? ☐ YES ☐ NO
6. ANY MISSING STANDPIPE VALVE WHEELS? ☐ YES ☐ NO WERE MISSING WHEELS REPLACED? ☐ YES ☐ NO
7. ALL HOSE CABINET DOORS HAVE VISUAL IDENTIFICATION GLASS PANELS? ☐ YES ☐ NO
8. HOSE CABINETS DOORS WITH NO GLASS PANELS HAVE APPROVED SIGN? ☐ YES ☐ NO
9. STANDPIPE THREADS COMPATIBLE WITH FIRE DEPT (N.S.T.)? ☐ YES ☐ NO  
THREADS FREE OF DAMAGE ☐ YES ☐ NO CONNECTIONS ACCESSIBLE ☐ YES ☐ NO
10. MAIN DRAIN TEST? ☐ YES ☐ NO ☐ N/A STATIC PRESSURE \_\_\_\_\_ PSI RESIDUAL PRESSURE \_\_\_\_\_ PSI
11. HYDROSTATIC TEST PERFORMED ☐ YES ☐ NO DATE OF LAST HYDROSTATIC TEST \_\_\_\_/\_\_\_\_/\_\_\_\_
12. 5-YEAR FLOW TEST PERFORMED ☐ YES ☐ NO IF YES, RECORD RESULTS BELOW:  
OUTLET USED \_\_\_\_\_ OUTLET SIZE ☐ 1 1/2" ☐ 2 1/2"  
STATIC PRESSURE \_\_\_\_\_ PSI RESIDUAL PRESSURE \_\_\_\_\_ PSI FLOW \_\_\_\_\_ GPM  
FLOW & PRESSURE ACCEPTABLE ☐ YES ☐ NO GAGES RECALIBRATED ☐ YES ☐ NO

DEFICIENCIES: \_\_\_\_\_

SIGNATURE OF INSPECTOR \_\_\_\_\_ DATE \_\_\_\_/\_\_\_\_/\_\_\_\_

SIGNATURE OF OWNER/REPRESENTATIVE \_\_\_\_\_ DATE \_\_\_\_/\_\_\_\_/\_\_\_\_